

No. SchneiderElectric\_Easergy\_P5M30\_V01\_Ed2

**Issued to:**

Schneider Electric Industries SAS  
35 rue Joseph Monier,  
92500 Rueil-Malmaison, France

**For the server product:**

Easergy P5M30  
Motor Protection  
Software version: V01

The server product has not been shown to be non-conforming to:

## IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL<sup>2</sup> 1.2.6 with product's protocol, model and technical issue implementation conformance statements: Schneider Electric Easergy P5 IEC61850 Server Conformance Statement Ed2: Chapter 2 PICS, Schneider Electric Easergy P5 IEC61850 Server Conformance Statement Ed2: Chapter 3 MICS, Schneider Electric Easergy P5 IEC61850 Server Conformance Statement Ed2: Chapter 5 TICS and product's extra information for testing: Schneider Electric Easergy P5 IEC61850 Server Conformance Statement Ed2: Chapter 4 PIXIT.


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (24/26)	9a GOOSE Publish (13/13)
2 Data Sets (4/7)	9b GOOSE Subscribe (12/14)
2+ Data Set Definition (24/24)	12a Direct Control (6/18)
4 Setting Group Selection (4/4)	12b SBO Control (12/27)
5 Unbuffered Reports (21/21)	12c Enhanced Direct Control (8/20)
6 Buffered Reports (30/30)	12d Enhanced SBO Control (13/28)
	13 Time Synchronization (4/7)

This Certificate includes a summary of the test results as carried out at Schneider Electric IEC61850 lab in China with UniCASim 61850 client simulator 4.31.02 with test suite v4.32.03 and UniCA Analyzer 5.31.00. This document has been issued for information purposes only, and the original paper copy of the Schneider Electric IEC61850 lab report: No. SchneiderElectric\_Easergy\_P5M30\_V01\_Ed2\_RPT will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to Schneider Electric IEC61850 lab by Schneider Electric. The manufacturer's production process has not been assessed. This certificate does not imply that Schneider Electric IEC61850 lab has certified or approved any product other than the specimen tested

Shanghai, April 30, 2019



Xiaohui WANG  
Ver&Val Section Manager

Issued by:




Chunyan YU  
IEC61850 Test Engineer

<sup>1</sup> Level B \_ Tester lab with certified ISO 9001 Quality System

<sup>2</sup> Test Procedure Change List

Copyright © Schneider Electric All right reserved. Please note that any electronic version of this Schneider Certificate is provided to Schneider's customer for convenience purpose only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts.

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL 1.2.6

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrv9, sSrv10, sSrv12, sSrvN1e, sSrvN1f, sSrvN2, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs11, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs12, sDsN11, sDsN12
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp15, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp13, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr15, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr13, sBr23, sBr24
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11	sGop1, sGop2b, sGop5, sGop6, sGop7, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl13, sCtl16
12b: SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOns1, sSBOns2, sSBOns6	sCtl6, sCtl16, sCtl27
12c: Enhanced Direct control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl13, sCtl14, sCtl16, sCtl26
12d: Enhanced SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOe1, sSBOe2, sSBOes6, sSBOes8	sCtl6, sCtl16, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	sTmN2